



The State of New Hampshire  
*Department of Environmental Services*



Michael P. Nolin  
Commissioner

LETTER OF DEFICIENCY

No. WD SS 06-005

March 31, 2006

Mr. Gary Trinqué  
654 Buckley Highway  
Union, CT 06076

RE: Septic on Property, Stewartstown, NH

Dear Mr. Trinqué:

On October 31, 2005, personnel from the Department of Environmental Services, Water Division ("DES") conducted an inspection of the West Stewartstown property, described as Lot #18 and Lot #19, on Tax Map # U5, and located on 1485 Big Diamond Pond Road, Stewartstown, NH, ("the Property"). The purpose of this inspection was to determine whether you were in compliance with RSA 482-A, RSA 483-B, and RSA 485-A and its implementing regulations, the Subdivision and Individual Sewage Disposal System Design Rules, Env-Ws 1000 ("the Rules").

As a result of the inspection, the following deficiency was noted:

1. A new structure has been constructed on the property in the form of a garage that appears to have living space built into it on the second floor. This space may increase the wastewater loading budget on the recently approved holding tank on the Property.

DES expects the above deficiency to be permanently corrected within 30 days by initiating and completing the following measures:

1. Because this new structure may lead to increased wastewater generation, DES needs to inspect the interior of the structure to determine its potential impact on the recently approved holding tank's ability to properly handle the wastewater generated on the Property.

**During interim between receipt of this letter and the date by which permanent corrections have been completed, as an alternate to vacating the premises, DES expects that collected sewage will be pumped and disposed in accordance with NH Administrative Rule Env-Ws 1600 at sufficient frequent intervals to prevent overflow. If this alternative is utilized, it is advised that pumping receipts be retained.**

DES believes the cited deficiencies will be corrected within 30 days and a report describing

the corrective measures can be submitted to this office within 40 days of receipt of this letter.

In the event compliance is not achieved within this period, DES may take further action against you, including issuing an order requiring the above items to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the New Hampshire Department of Justice for imposition of civil and/or criminal penalties. In addition, DES personnel will reinspect the Property within the stated period to determine whether you have come into, and are maintaining, full compliance with all applicable statutes and directives.

The written report as requested above should be addressed as follows:

Richard J. de Seve, SSB, DES  
Department of Environmental Services  
6 Hazen Drive, PO Box 95  
Concord, NH 03302-0095

Your prompt cooperation is appreciated. Should you have any questions regarding this letter, please contact Richard J. de Seve at 271-3442.

Sincerely,



William E. Evans, P.E.  
Administrator  
Subsurface Systems Bureau

WEE/RJD

**CERTIFIED MAIL 7099 3400 0002 9772 9950**

Cc: James G. Falicon, SSB, DES

Gretchen Hamel, Administrator, DES Legal Unit ✓

Board of Selectmen, Town of Stewartstown

Richard J. de Seve, SSB, DES

Linda Magoon, WB, DES